

## **SPECIFICATIONS:**

MINIMUM CONCRETE STRENGTH 4000 PSI @ 28 DAYS (PENNDOT CLASS AA) DW ENDWALL DESIGNED AS PER PENNDOT SPECIFICATION EXPOSED EDGES TO HAVE 1" X 1" CHAMFER MATERIALS AND WORKMANSHIP IN ACCORDANCE WITH THE REQUIREMENTS OF PENNDOT PUBLICATION 408 SECTION 605 & 714 STEEL REINFORCEMENT A615 GRADE 60 HORIZONTAL AND VERTICAL



## PENNDOT TYPE 'DW' ENDWALL FOR 12"ø, 15"ø & 18"ø PIPE

SIGNATURE OF APPROVAL	DATE AR	DWG	STRUCTURE
	2/08/16	DW1218	
	1 2/00/10		