



## **SPECIFICATIONS**

MINIMUM CONCRETE STRENGTH 4000 PSI @28 DAYS (PENNDOT CLASS AA) STEEL REINFORCEMENT —ASTM A615, GRADE 60. WELDED WIRE FABRIC:ASTM A185 (WALLS— 0.12 IN.²/VERTICAL FOOT). 1½" MIN. CONCRETE COVER (ALL REINFORCEMENT). MANHOLE DESIGN SPECIFICATIONS CONFORMS TO "PRECAST REINFORCED CONCRETE MANHOLE SECTIONS" ASTM C478, LATEST REVISIONS. MEETS HS—25 LOAD REQUIREMENTS.



72" Dia. TRANSITION FLAT LID w/ 48" Dia. MANHOLE OPENING

SIGNATURE OF APPROVAL	DATE	AR	DWG	STRUCTURE
	2/08/1	6	 72-48MHTI	