

SPECIFICATIONS

MINIMUM CONCRETE STRENGTH 4000 PSI @28 DAYS (PENNDOT CLASS AA) STEEL REINFORCEMENT —ASTM A615, GRADE 60.
WELDED WIRE FABRIC:ASTM A185 (WALLS— 0.12 IN.²/VERTICAL FOOT).
1½" MIN. CONCRETE COVER (ALL REINFORCEMENT).
MANHOLE DESIGN SPECIFICATIONS CONFORMS TO "PRECAST REINFORCED CONCRETE MANHOLE SECTIONS" ASTM C478, LATEST REVISIONS.
MEETS HS—25 LOAD REQUIREMENTS.



72" DIA. STORM SEWER MANHOLE

0	SIGNATURE OF APPROVAL	DATE AR D	WG	STRUCTURE
8		2/08/16	72MH	